

GOVERNMENT OF BIHAR
PUBLIC HEALTH ENGINEERING DEPARTMENT

P. H. Division, Supaul
Subdivisional Lab Birpur

WATER QUALITY TESTING REPORT

Location of Source :- Savitri Prabha Public School, Birpur (supaul)

Type of Sample :- Treated Water

Date of Sampling :- 10/12/2025

Date of Testing :- 11/12/2025

Sl. No.	PARTICULARS	PERMISSIBLE LIMIT	Obsrvation	Remarks
1	pH	6.5-8.5	7.04	
2	Turbidity	1-5 NTU	<1	
3	Conductivity		276	
4	TDS	500-2000 mg/L	168	
5	Total Hardness	300-600 mg/L	96.6	
6	Iron	1.0 - NR mg/L	0.15	
7	Bacteriological Test By H2S strip vial	Not Found	Note Found	

Note:- NR= No Relaxation

[Signature]
Chemist 11/12/2025
P.H. Sub Division, Birpur

[Signature]
11/12/2025
Assistant Engineer
P.H. Sub Division, Birpur